



## IBWA STANDARD OF QUALITY REPORT

**Customer name** CENTRAL VALLEY CULLIGAN  
**Customer Address** 2479 S ORANGE  
**Customer city, state** FRESNO, CA  
**Sample Date**  
**Sample Description** DRINKING WATER  
**Date reviewed** 2/7/2011

Page 1 of 11

**Sample I.D.** 1100205  
**Report Date** 2/7/2011

### Inorganic Chemicals (IOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
7440-36-0	Antimony (Sb)	N.D.	6	2	ug/l	200.8
7440-38-2	Arsenic (As)	N.D.	10	2	ug/l	200.8
7940-41-7	Beryllium (Be)	N.D.	4	0.1	ug/L	200.8
	Bromate by ICP	N.D.	10		ug/l	321.8
7440-43-9	Cadmium (Cd)	N.D.	5	0.1	ug/l	200.8
	chloramine	0.000	4		mg/L	999.9
	Chlorine, Total	0.0	0.1		mg/l	999.9
	chlorinedioxide	0.000	0.8		mg/L	999.9
	chlorite	N.D.			mg/L	
7440-47-3	Chromium (Cr)	N.D.	50	0.5	ug/l	200.8
16984-48-8	Fluoride (F)	N.D.	3	0.05	mg/l	300.0
7439-92-1	Lead (Pb)	N.D.	5	1	ug/l	200.8
7439-97-6	Mercury (Hg)	N.D.	1	0.2	ug/l	245.1
7440-02-0	Nickel (Ni)	N.D.	100	10	ug/l	200.8
	Nitrate As N (NO3)	N.D.	10	0.5	mg/l	300.0
	Nitrite As N (NO2)	N.D.	1	0.1	mg/l	300.0
	Perchlorate by IC	0.045	2		ug/L	314.1
7782-49-2	Selenium (Se)	N.D.	10	2	ug/l	200.8
7440-28-0	Thallium (Tl)	N.D.	2	1	ug/l	200.8

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

## IBWA STANDARD OF QUALITY REPORT

### Secondary Inorganic Parameters

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
7429-90-5	Aluminum (Al)	N.D.	200	2	ug/l	200.8
	Chloride (Cl)	0.8	250	0.5	mg/l	300.0
7440-50-8	Copper (Cu)	N.D.	1	0.003	mg/l	200.7
	Est TDS by Cond.	2.	500		ppm	999.9
7439-89-6	Iron (Fe)	N.D.	0.3	0.05	mg/l	200.7
7439-96-5	Manganese (Mn)	N.D.	0.05	0.02	mg/l	200.7
7440-22-4	Silver (Ag)	N.D.	25	0.1	ug/l	200.8
	Sulfate (SO4)	N.D.	250	3	mg/l	300.0
7440-66-6	Zinc (Zn)	N.D.	5	0.05	mg/l	200.7

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

## IBWA STANDARD OF QUALITY REPORT

<b>Volatile Organic Chemicals (VOCs)</b>						
CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
630-20-6	1,1,1,2-Tetrachloroethane	N.D.			ppb	524
71-55-6	1,1,1-Trichloroethane	N.D.	30	1	ppb	524
75-34-3	1,1-Dichloroethane	N.D.			ppb	524
75-35-4	1,1-Dichloroethene	N.D.	2	1	ppb	524
	1,1-Dichloropropane	N.D.			ppb	524
563-58-6	1,1-Dichloropropene	N.D.			ppb	524
	1,2,3-Trichlorobenzene	N.D.			ppb	524
96-18-4	1,2,3-Trichloropropane	N.D.			ppb	524
120-82-1	1,2,4-Trichlorobenzene	N.D.	9	1	ppb	524
	1,2,4-Trimethylbenzene	N.D.			ppb	524
96-12-8	1,2-Dibromo-3-chloropropa	N.D.			ppb	524
95-50-1	1,2-Dichlorobenzene	N.D.			ppb	524
107-06-2	1,2-Dichloroethane	N.D.	2	1	ppb	524
78-87-5	1,2-Dichloropropane	N.D.	5	1	ppb	524
79-00-5	1,2-Trichloroethane	N.D.			ppb	524
	1,3,5-Trimethylbenzene	N.D.			ppb	524
541-73-1	1,3-Dichlorobenzene	N.D.			ppb	524
142-28-9	1,3-Dichloropropane	N.D.			ppb	524
106-46-7	1,4-Dichlorobenzene	N.D.			ppb	524
590-20-7	2,2-Dichloropropane	N.D.			ppb	524
95-49-8	2-Chlorotoluene	N.D.			ppb	524
591-78-6	2-Hexanone	N.D.			ppb	524
106-43-4	4-Chlorotoluene	N.D.			ppb	524
67-64-1	Acetone	N.D.			ppb	524

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

## IBWA STANDARD OF QUALITY REPORT

Volatile Organic Chemicals (VOCs)						
CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
71-43-2	Benzene	N.D.	1	1	ppb	524
108-86-1	Bromobenzene	N.D.			ppb	524
74-97-5	Bromochloromethane	N.D.			ppb	524
75-27-4	Bromodichloromethane	N.D.			ppb	524
75-25-2	Bromoform	N.D.			ppb	524
74-83-9	Bromomethane	N.D.			ppb	524
75-15-0	Carbon Disulfide	N.D.			ppb	524
56-23-5	Carbon Tetrachloride	N.D.	5	1	ppb	524
108-90-7	Chlorobenzene	N.D.			ppb	524
75-00-3	Chloroethane	N.D.			ppb	524
67-66-3	Chloroform	N.D.			ppb	524
74-87-3	Chloromethane	N.D.			ppb	524
156-59-4	Cis-1,2-Dichloroethene	N.D.	70	1	ppb	524
10061-01-5	cis-1,3-Dichloropropene	N.D.			ppb	524
124-48-1	Dibromochloromethane	N.D.			ppb	524
74-95-3	Dibromomethane	N.D.			ppb	524
75-71-8	Dichlorochlorodifluorometh	N.D.			ppb	524
75-09-2	Dichloromethane	N.D.			ppb	524
100-41-4	Ethylbenzene	N.D.	700	1	ppb	524
74-88-4	Iodomethane	N.D.			ppb	524
98-82-8	Isopropylbenzene	N.D.			ppb	524
	m,p-Xylene	N.D.			ppb	524
78-93-3	Methyl Ethyl Ketone	N.D.			ppb	524
108-10-1	Methyl Isobutyl Ketone	N.D.			ppb	524

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

## IBWA STANDARD OF QUALITY REPORT

Volatile Organic Chemicals (VOCs)						
CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
	n-Butylbenzene	N.D.			ppb	524
	n-Propylbenzene	N.D.			ppb	524
95-47-6	o-Xylene	N.D.			ppb	524
	p-iso-Propyltoluene	N.D.			ppb	524
	sec-Butylbenzene	N.D.			ppb	524
100-42-5	Styrene	N.D.	100	1	ppb	524
127-18-4	Tetrachloroethene	N.D.	1	1	ppb	524
108-88-3	Toluene	N.D.	1000	1	ppb	524
156-60-5	Trans-1,2-Dichloroethene	N.D.	100	1	ppb	524
10061-02-6	trans-1,3-Dichloropropene	N.D.			ppb	524
79-01-6	Trichloroethene	N.D.	1	1	ppb	524
75-69-4	Trichlorofluoromethane	N.D.			ppb	524
108-05-4	Vinyl Acetate	N.D.			ppb	524
75-01-4	Vinyl Chloride	N.D.	2	1	ppb	524

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

Sample I.D. 1100205  
Report Date 2/7/2011

## IBWA STANDARD OF QUALITY REPORT

Page 6 of 11

### Synthetic Organic Chemicals (SOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
	Synthetic organic chemical	N.D.				999.9

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

Certifications: CA-06249CA; IL-100213; NY-11756; MT-CERT0091; TX-TX269-2007A  
IA-369; VT-VT02199 NELAP Accredited

Richard Cook  
Manager Analytical Laboratory

## IBWA STANDARD OF QUALITY REPORT

### Additional Regulated Contaminants

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
79-34-5	1,1,2,2-Tetrachloroethane	N.D.	1		ppb	524
1634-04-4	Methyl t-butyl ether	N.M.	70		ppb	524
91-20-3	Naphthalene	N.D.	300		ppb	524
7440-61-1	Uranium by ICP MS	N.D.	30		ug/L	200.8

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

## IBWA STANDARD OF QUALITY REPORT

<b>Water Properties</b>						
CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
	Color After Acidific	N.M.	5	5		999.9
	Color As Received	N.D.	5	5		999.9
	Conductivity	3.			MMHOS	999.9
	pH	4.8	5 - 8.5			150.1
	Turb After Filtered	N.M.	0.5		NTU	180.1
	Turbidity As Rec'd	0.2	0.5		NTU	180.1

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

## IBWA STANDARD OF QUALITY REPORT

### Radiological Contaminants

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
	Gross Alpha Beta U	N.D.				999.9

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

## IBWA STANDARD OF QUALITY REPORT

<b>Hardness</b>						
CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
7440-70-2	Calcium (Ca)	N.D.		0.1	mg/l	200.7
7439-95-4	Magnesium (Mg)	N.D.		0.1	mg/l	200.7
7440-23-5	Sodium (Na)	N.D.		0.1	mg/l	200.7
	Total Hardness	N.D.		0.6	mg/l	200.7

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

**IBWA STANDARD OF QUALITY REPORT**

<b>Uncategorized</b>						
CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method
	Bromide by ICP	Not Present			ug/L	321.8
	Chlorine, Free	0.0			mg/l	
	Haloacetic Acids	N.D.			ppm	
	M for Alkalinity	0.2			ppm	999.9
	P for Alkalinity	N.M.			ppm	999.9
	pesticide_herb	N.D.				999.9
7440-09-7	Potassium (K)	N.D.		0.1	mg/l	200.7
7440-24-6	Strontium (Sr)	N.D.		0.05	mg/l	200.7
	Tannins mg/l	N.D.		2	mg/l	999.9

N.D. - Indicates that the compound was not detected above the Lab's Reporting Limit - MRL

N.M. - Indicates that the compound was not measured.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

pH – the acid strength of water on a scale of 0 to 14 (neutral = pH 7.0). Values from 7→0 are increasingly more acidic; values from 7→14 are increasingly more alkaline. The recommended range for drinking water under the U.S. regulations is 6.5 to 8.5.

Conductivity – the relative ability of water to carry an electrical current, used to estimate the total concentration of dissolved ions.

Turbidity – cloudiness in water caused by the dispersion of light by extremely tiny particles. Measured on an arbitrary scale of Nephelometric Turbidity Units (NTUs). The mandatory maximum under U.S. regulations is 0.5 NTU.

Color – the amount of brownish-yellow color from dissolved tannins from vegetation (like tea) and metals (like rust) and their combinations, measured on an arbitrary scale. The recommended maximum under U.S. regulations is 15 CU.

Silica, SiO<sub>2</sub> – a naturally occurring dissolved mineral, which produces a glassy scale in high temperature equipment but is more important in predicting the life of certain water treatment media.

Hydrogen Sulfide, H<sub>2</sub>S – a toxic, noxious, corrosive gas that smells like rotten eggs. Bacteria acting on sulfate or organic sulfur-containing materials in the absence of oxygen produce it. Only “special” water analyses can determine hydrogen sulfide levels.

Total Hardness – the sum of all metal ions which react with soap to inhibit sudsing and form “scum” or “bathtub ring” – mostly Calcium and Magnesium. When heated or evaporated, hard water can cause lime scale that can deposit on sink and shower fixtures and walls and result in loss in efficiency or fuel waste in water heaters, boilers, and cooling systems.

Total Alkalinity – the sum of hydroxide (OH<sup>-</sup>), carbonate (CO<sub>3</sub><sup>-2</sup>), and bicarbonate (HCO<sub>3</sub><sup>-</sup>) ions, which can combine with both acids and bases, which act to buffer water and prevent sudden uncontrolled changes in pH.

Cations – ions (atoms or molecules with an electrical charge) with a positive (+) electrical charge, so named because they go toward the cathode in an electric field. Besides the hardness ions, the main cations in water are sodium, Na<sup>+</sup>, and potassium, K<sup>+</sup>.

Anions – ions (atoms or molecules with an electrical charge) with a negative (-) electrical charge, so named because they go toward the anode in an electric field. The main anions in water are hydroxide (OH<sup>-</sup>), carbonate (CO<sub>3</sub><sup>-2</sup>), bicarbonate (HCO<sub>3</sub><sup>-</sup>) (which together comprise “alkalinity”), sulfate (SO<sub>4</sub><sup>-2</sup>), nitrate (NO<sub>3</sub><sup>-</sup>) and chloride (Cl<sup>-</sup>).

Nitrate/Nitrite, NO<sub>3</sub><sup>-</sup>/NO<sub>2</sub><sup>-</sup> – important because of toxicity to infants, nitrate comes from fertilizers and animal wastes. Water supplies with high nitrate levels should also be screened for agricultural pesticides and bacterial contamination. The mandatory limit under U.S. regulations is 10 mg/L.

Sulfate, SO<sub>4</sub><sup>-2</sup> – a common mineral component, only rarely occurring at excessive levels, which can cause a temporary diarrhea in visitors who have not become acclimated to it. Recommended U.S. limit, 250 mg/L.

Fluoride, F<sup>-</sup> – often added to water to inhibit tooth decay. Mandatory U.S. limits range from 4.0 mg/L in northern regions to 1.4 mg/L in southern regions (where more water is consumed).

Chloride, Cl<sup>-</sup> – a common mineral component, can be found in elevated levels near seawater and other salt supplies, which can cause taste problems and can contribute to corrosion. Recommended U.S. limit, 250 mg/L.

Iron, Fe – cause of metallic taste, rust stains on laundry and porcelain fixtures, and clogging/fouling of equipment. The recommended U.S. limit is 0.3 mg/L.

Manganese, Mn – cause of metallic taste and black stains on laundry and porcelain. Often occurs in combination with iron. The recommended U.S. limit is 0.05 mg/L Mn or a total of 0.3 mg/L of Fe + Mn.

Copper, Cu – cause of green stains on porcelain and fittings, seldom naturally -occurring, usually due to corrosion. The mandatory U.S. “action level” of 1.3 mg/L is tied to the regulation for lead contamination due to corrosion of plumbing materials.

Zinc, Zn – cause of metallic taste and upset stomach. Due to corrosion of galvanized plumbing materials. Recommended U.S. limit, 5.0 mg/L.

#### Units of Concentration used in this Report

gpg-abbreviation for “grains per gallon” calculated in terms of calcium carbonate equivalents. Multiply by 17.12 to convert gpg into either ppm or mg/L.

ppm-abbreviation for “parts per million.” Interchangeable with mg/L.

mg/L-abbreviation for “milligrams per liter.” Interchangeable with ppm. (There are one million milligrams in a liter of pure water).

ppb-abbreviation for “parts per billion.” Interchangeable with µg/L or micrograms per liter.

µg/L-abbreviation for “micrograms per liter.” Interchangeable with ppb. (There are a billion micrograms in a liter).

$$1000 \text{ ppb} = 1 \text{ ppm}; 1000 \text{ µg/L} = 1 \text{ mg/L}$$

THIS ANALYSIS WILL NOT DETERMINE WHETHER A WATER IS SAFE FOR HUMAN CONSUMPTION

BW

S  
Culligan Inter

1100205

Control

**SAMPLE SUBMITTED BY:**

Account Number: 04358  
Account Name: Central Valley Culligan  
Phone Number: 559-233-3055 X 211  
FAX Number:  
E-Mail:  
Person Taking Sample:  
Date Sample Taken: Time Sample Taken:

**CUSTOMER INFORMATION:**

Customer Name:  
Store Name:  
Customer Account Number:  
Address: 2479 S Orange  
City: FRESNO State: ~~CA~~ CA Zip: 93725  
Customer reported concern:

**SAMPLE INFORMATION:**

Water Supply: Private                      Municipal  
Source: Surface                              Well                              Unknown  
Condition: Treated                          Untreated                      Cloudy                      Colored                      Odor  
Sample Point: Faucet                          Equipment                      Other  
Application: Household                      Commercial                      National Account

Comments:

**ANALYSIS REQUESTED:**

Standard Analysis:                      Standard w/TOC:                      Scale Analysis:  
Hemodialysis Basic:                      Brine Analysis:  
Hemodialysis Complete:                      Depth Filter Analysis:  
Resin Analysis:                              Performed at Rockford Laboratories  
Special Analysis: (List Analysis Requested): IBWA test                      DRINKING WATER  
For Questions or Special Analysis contact Rick Cook at (847) 430-1284                      3 gal

**EQUIPMENT INVOLVED (IF ANY):**

**LAB USE ONLY:**  
Sample received in acceptable condition: Yes                      No  
Received by:                                      Date:                                      Time:                                      No paperwork,  
If not reason:                                      6-25-07 01:10:15  
Disposition of sample.

Litigation samples are not accepted by the laboratory

Customer  
Please sign: Culligan International Company  
Please print your name: By:  
Its:



Burlington WA  
Corporate Office

1620 S Walnut St - 98253  
360.755.4295 • 360.757.1450

Bellingham WA  
Microbiology

605 W Orchard Dr Ste 4  
360.671.0636

Portland OR  
Microbiology/Chemistry

9150 SW Pioneer Ct Ste W-37970  
503.882.7800



## IBWA STANDARD OF QUALITY REPORT

Client Name: Culligan International Company  
9399 W. Higgins Rd. Suite B2  
Rosemont, IL 60018

Reference Number: **11-00262**

Project: 1100205

Field ID: 1100205

Sample Description:

Sampled By: Daniela Irimia

Sample Date: 01/05/2011

Lab Number: 551

Report Date: 02/02/2011

Reviewed By:

Lawrence J  
Henderson, PhD  
2011.02.05  
11:09:09 -08'00'

### Inorganic Chemicals (IOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Analyzed	COMMENT
57-12-5	CYANIDE	ND	0.1	0.040	mg/L	SM4500-CN F	1/11/11	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL  
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA  
MRL - Method Reporting Limit

An \* in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.  
If you have any questions concerning this report contact us at the above phone number.



Reference Number: **11-00262**  
 Lab Number: **551**  
 Report Date: **02/02/2011**

## IBWA STANDARD OF QUALITY REPORT

Page 2 of 5

### Synthetic Organic Chemicals (SOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Analyzed	COMMENT
93-72-1	* 2,4,5 - TP (SILVEX)	ND	10	0.4	ug/L	515.4	1/17/11	
94-75-7	* 2,4 - D	ND	70	0.2	ug/L	515.4	1/17/11	
15972-60-8	ALACHLOR	ND	2	0.4	ug/L	525.2	1/14/11	
116-06-3	ALDICARB	ND	3	1	ug/L	531.2	1/19/11	
1646-88-4	ALDICARB SULFONE	ND	3	1	ug/L	531.2	1/19/11	
1646-87-3	ALDICARB SULFOXIDE	ND	4	1	ug/L	531.2	1/19/11	
1912-24-9	ATRAZINE	ND	3	0.2	ug/L	525.2	1/14/11	
1563-66-2	CARBOFURAN	ND	40	1	ug/L	531.2	1/19/11	
57-74-9	CHLORDANE	ND	2	0.4	ug/L	525.2	1/14/11	
96-12-8	DIBROMOCHLOROPROPANE (DBCP)	ND	0.2	0.04	ug/L	504.1	1/12/11	
88-85-7	* DINOSEB	ND	7	0.4	ug/L	515.4	1/17/11	
72-20-8	ENDRIN	ND	2	0.02	ug/L	525.2	1/14/11	
106-93-4	ETHYLENE DIBROMIDE (EDB)	ND	0.05	0.02	ug/L	504.1	1/12/11	
76-44-8	HEPTACHLOR	ND	0.4	0.08	ug/L	525.2	1/14/11	
1024-57-3	HEPTACHLOR EPOXIDE "B"	ND	0.2	0.04	ug/L	525.2	1/14/11	
58-89-9	LINDANE (BHC - GAMMA)	ND	0.2	0.04	ug/L	525.2	1/14/11	
72-43-5	METHOXYCHLOR	ND	40	0.2	ug/L	525.2	1/14/11	
23135-22-0	OXYMAL (VYDATE)	ND	200	1	ug/L	531.2	1/19/11	
87-86-5	* PENTACHLOROPHENOL	ND	1	0.08	ug/L	515.4	1/17/11	
1918-02-1	* PICLORAM	ND	500	0.2	ug/L	515.4	1/17/11	
1336-36-3	POLYCHLORINATED BIPHENYLS (PCB)	ND	0.5	0.2	ug/L	508.1	1/14/11	
75-99-0	* DALAPON	ND	200	2	ug/L	515.4	1/17/11	
122-34-9	SIMAZINE	ND	4	0.15	ug/L	525.2	1/14/11	
8001-35-2	TOXAPHENE	ND	3	1	ug/L	508.1	1/14/11	
85-00-7	DIQUAT	ND	20	2	ug/L	549.2	1/11/11	
145-73-3	ENDOTHALL	ND	100	20	ug/L	548.1	1/14/11	
1071-83-6	GLYPHOSATE	ND	700	10	ug/L	547	1/10/11	
50-32-8	BENZO(A)PYRENE	ND	0.2	0.04	ug/L	525.2	1/14/11	
103-23-1	DI(ETHYLHEXYL)-ADIPATE	ND	400	1.3	ug/L	525.2	1/14/11	
118-74-1	HEXACHLOROBENZENE	ND	1	0.2	ug/L	525.2	1/14/11	
77-47-4	HEXACHLOROCYCLO-PENTADIENE	ND	50	0.2	ug/L	525.2	1/14/11	
117-81-7	DI(ETHYLHEXYL)-PHTHALATE	ND	6	1.3	ug/L	525.2	1/14/11	

**Notation:**

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL  
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDES or IBWA  
 MRL - Method Reporting Limit

An \* in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10

**These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.**



Reference Number: 11-00262  
Lab Number: 551  
Report Date: 02/02/2011

## IBWA STANDARD OF QUALITY REPORT

Page 3 of 5

### Halo-Acetic Acids

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Analyzed	COMMENT
79-11-8	* Monochloroacetic Acid	ND		2	ug/L	552.3	1/13/11	
79-43-6	* Dichloroacetic Acid	ND		1	ug/L	552.3	1/13/11	
76-03-9	* Trichloroacetic Acid	ND		1	ug/L	552.3	1/13/11	
79-08-3	* Monobromoacetic Acid	ND		1	ug/L	552.3	1/13/11	
631-64-1	* Dibromoacetic Acid	ND		1	ug/L	552.3	1/13/11	
NA	* HAA(5)	ND	60	1	ug/L	552.3	1/13/11	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL  
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDR or IBWA  
MRL - Method Reporting Limit

An \* in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.



Reference Number: 11-00262

Lab Number: 551

Report Date: 02/02/2011

## IBWA STANDARD OF QUALITY REPORT

Page 4 of 5

### Other

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Analyzed	COMMENT
5589-96-3	* Bromochloroacetic Acid	ND		1	ug/L	552.3	1/13/11	

#### Notation

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality - maximum permissible level of a contaminant in water established by EPA, NPDR or IBWA.

MRL - Method Reporting Limit

An \* in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.



Reference Number: **11-00262**

Lab Number: **551**

Report Date: **02/02/2011**

## IBWA STANDARD OF QUALITY REPORT

Page 5 of 5

### Radiological Contaminants

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Analyzed	COMMENT
12587-46-1	* GROSS ALPHA	ND	15	3	pCi/L	900.0	1/26/11	Analyzed by Pace Labs
12587-47-2	* GROSS BETA	ND	50	4	pCi/L	900.0	1/26/11	Analyzed by Pace Labs
13982-63-3	* RADIUM 226	ND		1	pCi/L	903.1	1/28/11	Analyzed by Pace Labs
15262-20-1	* RADIUM 228	ND	5	1	pCi/L	904.0	2/1/11	Analyzed by Pace Labs

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDR or IBWA

MRL - Method Reporting Limit

An \* in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.